


PROVIDE 3-5/8"x20 GA.STUD DIAG. BRACING AT 4'-0" O.C. TO STRUCTURE ABOVE FOR EVERY 8 LINEAL FEET OF WALLS UNSUPPORTED BY PERPENDICULAR WALLS. ALTERNATE DIAGONAL BRACING WHERE REQUIRED

PROVIDE 6"THICK X 48"WIDE ACOUSTICAL SOUND BATTS, AS SHOWN



- REF. RCP

SUSPENDED ACOUSTICAL CEILNG TILE AND GRID



RUBBER BASE

3-5/8" QR 6"X20 GA. STUDS AT 16" O.C. PAINTED $\frac{1}{8}$ " GYP. BD. EA SIDE

1/4" ø x 1" L RAMSET/REDHEAD POWDER ACTUATED FASTENERS AT 48" O.C. PER ICBO #1639. ATTACH TO SLAB



WALL AT 6" ABOVE CEILING TILE

REV. NO.	000	DWG. NO.	
REV. DATE:	02-01-2021		AW-03
DRAWN BY :	NBS	SCALE:	1 1/2" = 1'-0"