

1 **BEFORE THE ARIZONA POWER PLANT**
2 **AND TRANSMISSION LINE SITING COMMITTEE**

3 In the matter of the Application of Salt)
4 River Project Agricultural Improvement and)
5 Power District in conformance with the)
6 requirements of Arizona Revised Statutes)
7 Sections 40-360-03 and 40-360.06, for a)
8 Certificate of Environmental Compatibility)
9 authorizing the Expansion of its Santan)
10 Generating Station, located at the intersection)
11 of Warner Road and Val Vista Drive,)
12 in Gilbert, Arizona, by adding 825 megawatts)
13 of new capacity in the form of three combined)
14 cycle natural gas units, and associated)
15 intraplant transmission lines.)
16 _____)

Case No. 105

Docket No. L-00000B-00-0105

Decision No. _____

17 **CERTIFICATE OF ENVIRONMENTAL COMPATIBILITY**

18 Pursuant to notice given as provided by law, the Arizona Power Plant and
19 Transmission Line Siting Committee (the "Committee") held public hearings at the
20 Dobson Ranch Inn, 1644 South Dobson Road, Mesa, Arizona, on September 14, 2000,
21 and various days following, in conformance with the requirements of Arizona Revised
22 Statutes section 40-360 *et seq.*, for the purpose of receiving evidence and deliberating
23 on the Application of Salt River Project Agricultural Improvement and Power District
24 ("Applicant") for a Certificate of Environmental Compatibility in the above-captioned
25 case (the "Application").

The following members or designees of members of the Committee were present
for the hearing on the Application:

Paul A. Bullis Chairman, Designee for Arizona Attorney General Janet Napolitano

Steve Olea Designee of Chairman of the Arizona Corporation Commission

1	Richard Tobin	Designee for the Arizona Department of Environmental Quality
2		
3	Dennis Sundie	Designee for the Director of the Department of Water Resources
4		
5	Mark McWhirter	Designee for the Director of the Energy Office of the Arizona Department of Commerce
6		
7	George Campbell	Appointed Member
8	Jeff Mcguire	Appointed Member
9	A. Wayne Smith	Appointed Member
10	Sandie Smith	Appointed Member
11	Mike Whalen	Appointed Member

11 The Applicant was represented by Kenneth C. Sundlof, Jr., Jennings, Strouss &
12 Salmon PLC. There were seventeen intervenors: Arizona Utilities Investor Association,
13 by Ray Heyman; Arizona Corporation Commission Staff, by Janice Alward; Arizona
14 Center for Law in the Public Interest, by Timothy Hogan, Mark Kwiat, Elisa Warner,
15 David Lundgreen, Cathy LaTona, Sarretta Parrault, Mark Sequeira, Cathy Lopez,
16 Michael Apergis, Marshal Green, Charlie Henson, Jennifer Duffany, Christopher
17 Labban, Bruce Jones and Dale Borger. There were a number of limited appearances.

18 The Arizona Corporation Commission has considered the grant by the Power
19 Plant and Line Siting Committee of a Certificate of Environmental Compatibility to SRP
20 and finds that the provisions of A.R.S. §40-360.06 have complied with, and, in addition,
21 that documentary evidence was presented regarding the need for the Santan Expansion
22 Project. Credible testimony was presented concerning the local generation deficiency in
23 Arizona and the need to locate additional generation within the East Valley in order to
24 minimize transmission constraints and ensure reliability of the transmission grid. The
25 evidence included a study that assessed the needs of the East Valley. The analysis

1 found that the East Valley peak load currently exceeds the East Valley import capability
2 and within the next 5 years the East Valley load will exceed the load serving capability.

3 Additional testimony was presented regarding SRP's projected annual 3.7% load
4 growth in its service territory. By 2008, SRP will need approximately 2700 MW to meet
5 its load. This local generation plant will have power available during peak periods for
6 use by SRP customers.

7 At the conclusion of the hearing and deliberations, the Committee, having
8 received and considered the Application, the appearance of Applicant and all
9 intervenors, the evidence, testimony and exhibits presented by Applicant and all
10 intervenors, the comments made by persons making limited appearances and the
11 comments of the public, and being advised of the legal requirements of Arizona Revised
12 Statutes Sections 40-360 to 40-360.13, upon motion duly made and seconded, voted to
13 grant Applicant the following Certificate of Environmental Compatibility (Case No. L-
14 00000B-00-0105):

15 Applicant and its assignees are granted a Certificate of Environmental
16 Compatibility authorizing the construction of an 825 megawatt generating facility
17 consisting of three combined cycle units with a total net output of 825 megawatts
18 together with related infrastructure and appurtenances, in the Town of Gilbert, on
19 Applicant's existing Santan Generating Station site, and related switchyard and
20 transmission connections, as more specifically described in the Application (collectively,
21 the "Project"). Applicant is granted flexibility to construct the units in phases, with
22 different steam turbine configurations, and with different transmission connection
23 configurations, so long as the construction meets the general parameters set forth in the
24 application.
25

1 This certificate is granted upon the following conditions:

- 2 1. Applicant shall comply with all existing applicable air and water pollution
3 control standards and regulations, and with all existing applicable
4 ordinances, master plans and regulations of the State of Arizona, the
5 Town of Gilbert, the County of Maricopa, the United States, and any other
6 governmental entities having jurisdiction.

7 ***Status ~ SRP has completed all the permitting requirements for this
8 project and is in compliance with all ordinances, master plans and
9 regulations of all applicable governmental jurisdictions.***

- 10 2. This authorization to construct the Project will expire five (5) years from
11 the date the Certificate is approved by the Arizona Corporation
12 Commission unless construction of the Project is completed to the point
13 that the project is capable of operating at its rated capacity; provided,
14 however, that Applicant shall have the right to apply to the Arizona
15 Corporation Commission for an extension of this time limitation.

16 ***Status ~ Unit 5 (the 2-on-1 units) began commercial operation on April
17 1, 2005. Unit 6 remains on schedule for commercial operation by April
18 30, 2006. Once completed, the Santan Expansion Project will add
19 significant new capacity to the valley and to SRP's energy resource
20 portfolio.***

21 ***The CEC for the Santan Expansion Project authorizes the construction
22 of "three combined cycle units with a total net output of 825
23 megawatts." The CEC does not specifically delineate the ambient
24 conditions or other assumptions underlying the total net output of 825
25 megawatts. It is recognized in the industry that: (1) manufacturers'
specifications include a design margin to ensure that guarantees will be
met; (2) that plant output can vary at different ambient conditions; and
(3) that the plant output will degrade over time.***

***SRP estimates the final net output of the three units, once the final unit
becomes operational in April 2006, will exceed 825 megawatts under
certain ambient and operating conditions. This estimate is based on
the manufacturer's ratings for the units and an estimate for the total
auxiliary load.***

***Regardless of the plant's achieved output, SRP will be bound by and
comply with the CEC conditions, including the environmental permit
levels issued by the Arizona Department of Environmental Quality, the
Arizona Department of Water Resources, the Maricopa County
Environmental Services Department and the Environmental Protection
Agency. SRP will not exceed such levels. SRP has shared this
information with the ACC Staff and the ACC Staff believes SRP is in
compliance with the CEC for the Santan Expansion Project, Case 105
(Decision No. 63611).***

- 1 3. Applicant's project has two (2) approved transmission lines emanating
2 from its power plant's transmission switchyard and interconnecting with
3 the existing transmission system. This plant interconnection must satisfy
4 the single contingency criteria (N-1) without reliance on remedial action
5 such as a generator unit tripping or load shedding.

6 **Status ~ SRP has completed the activity required by this condition.**

- 7 4. Applicant shall use reasonable efforts to remain a member of WSCC, or
8 its successor, and shall file a copy of its WSCC Reliability Criteria
9 Agreement or Reliability Management System (RMS) Generator
10 Agreement with the Commission.

11 **Status ~ SRP is currently a member of the WECC, the successor to the
12 WSCC, and plans to continue its membership with the WECC.**

- 13 5. Applicant shall use reasonable efforts to remain a member of the
14 Southwest Reserve Sharing Group, or its successor.

15 **Status ~ SRP is currently a member of the Southwest Reserve Sharing
16 Group and plans to continue its membership.**

- 17 6. Applicant shall meet all applicable requirements for groundwater set forth
18 in the Third Management Plan for the Phoenix Active Management Area.

19 **Status ~ SRP is in compliance with all requirements for groundwater, as
20 set forth in the Third Management Plan for the Phoenix Active
21 Management Area.**

- 22 7. With respect to landscaping and screening measures, including the
23 improvements listed in the IGA, Applicant agrees to develop and
24 implement a public process consistent with the process chart (Exhibit 89)
25 presented during the hearings, modifying the dates in the IGA with the
 Town of Gilbert, if necessary, to correspond with the schedule in Exhibit
 89.

 The new Community Working Group (CWG) will consist of 12 members,
 selected as follows: one member selected by the Town of Gilbert, four
 members selected by neighborhood homeowner associations, four
 representatives selected by intervenors, and three members selected by
 SRP (not part of the aforementioned groups) who were part of the original
 community working group. Applicant and landscaping consultants shall
 act as advisors to the CWG. CWG meetings shall be noticed to and be
 open to the general public. The initial meeting shall take place on an
 evening or weekend in the Town of Gilbert.

 The objective of the CWG shall be to refine the landscaping and mitigation

1 concept plans submitted during these hearings (Exhibit 88). The CWG shall
2 work to achieve appropriate visual mitigation of plant facilities and to
3 facilitate the design and installation of the concept plan components so as to
4 maximize the positive impact on the community and to increase, wherever
5 possible, the values of the homes in the neighboring areas. The refinement
6 of the mitigation plans shall be reasonably consistent with the planning
7 criteria of the Town of Gilbert, the desires of neighboring homeowner
8 associations, and the reasonable needs of Applicant.

9 Applicant shall retain an independent facilitator, acceptable to the CWG, to
10 conduct the CWG meetings. It shall be the role of the facilitator to assist in
11 initial education and in conducting an orderly and productive process. The
12 facilitator may, if necessary, employ dispute resolution mechanisms.

13 The CWG shall also assist in establishing reasonable maintenance
14 schedules for landscaping of Applicant's plant site in public-view areas.

15 Applicant will develop with the Town of Gilbert a continuous fund, to be
16 administered by the Town of Gilbert, to provide for the construction and
17 maintenance of off-site landscaping in the areas depicted in the off-site
18 landscaping concepts as developed by the CWG in an amount sufficient to
19 fund the concepts in Exhibit 88 or concepts developed by the CWG,
20 whichever is greater.

21 **Status ~**

22 **Onsite Landscaping Program ~**

23 ***SRP has completed nearly all of the landscaping at the site. The only
24 work not completed involves the northeast area and the southeast
25 corner of the project site that must be left available for construction
access or installation of underground utilities associated with the plant
construction. Landscaping work in the northeast and southeast areas
will be completed following the completion of Unit 6 construction.***

***The "Trails Area" (equestrian and bike trail) to the east of the power
plant is complete. SRP transferred ownership of the Trails Area to the
Town of Gilbert on September 13, 2005.***

Home Owners' Association (HOA) Offsite Landscaping Program ~

***SRP has completed the initial funding for this program, providing a one-
time payment to eighteen (18) HOAs in the area for use in providing
additional landscaping to help mitigate views of the power plant.***

***Under the program, SRP committed to making future annual payments
of \$49,884 to the HOAs for offsite landscaping maintenance for a period
of twenty (20) years, beginning in September 2004.***

Individual County Landscaping Program ~

SRP has completed this program.

- 1 8. The visual mitigation efforts shall be in general compliance with the plans
2 and concepts presented in these proceedings and constitute a commitment
3 level by Applicant. Applicant will not reduce the overall level of mitigation as
4 set forth in its Application and this proceeding, except as may be reasonably
changed during the CWG process. The Town of Gilbert shall approve the
plans agreed to by the CWG.

5 ***Status ~ SRP has satisfied the visual mitigation requirements as***
6 ***initially set forth in the Application and the proceeding and further***
7 ***refined and expanded during the CWG process. SRP's mitigation***
efforts also include the items specified in the SRP/Town of Gilbert
Intergovernmental Agreement.

- 8 9. Applicant shall, where reasonable to do so, plant on site trees by the fall of
9 2001. Because planting of trees must await the improvement of Warner
10 Road and the design and construction of berms, this condition will largely
11 apply to trees on the East side of the site, and some of the trees on the
12 North side. All landscaping will be installed prior to the installation of major
plant equipment such as, but not limited to, exhaust stacks, combustion
turbines, and heat recovery steam generators, except where delays are
reasonably necessary to facilitate construction activities.

13 ***Status ~ As noted in condition 7, nearly all of the landscaping work at***
14 ***the site has been completed. Following the completion of Unit 6***
construction, SRP will complete the landscaping work in the northeast
area and the southeast corner of the project site.

- 15 10. Applicant shall operate the Project so that during normal operations the
16 Project shall not exceed the most restrictive of applicable (i) HUD residential
17 noise guidelines, (ii) EPA residential noise guidelines, or (iii) applicable City
18 of Tempe standards. Additionally, construction and operation of the facility
19 shall comply with OSHA worker safety noise standards. Applicant agrees
20 that it will use its best efforts to avoid during nighttime hours construction
21 activities that generate significant noise. Additionally, Applicant agrees to
22 comply with the standards set forth in the Gilbert Construction Noise
Ordinance, Ordinance No. 1245, during construction of the project. In no
case shall the operational noise level be more than 3 db above background
noise as of the noise study prepared for this application. The Applicant shall
also, to the extent reasonably practicable, refrain from venting between the
hours of 10:00 p.m. and 7:00 a.m.

23 ***Status ~ SRP remains in compliance with all applicable noise guidelines***
24 ***and standards. Throughout construction of the project, SRP has taken***
noise readings at various locations along the plant boundary three
25 ***times per week to ensure compliance with noise guidelines and***
standards. Additional noise testing is conducted during nighttime
construction activities, such as concrete pours. This process will
continue until the commercial operation of Unit 6.

1 ***Unit 5 began commercial operation on April 1, 2005 and plant personnel***
2 ***are conducting additional off-site noise testing at the three sites***
3 ***designated by the Santan Neighborhood Committee (SNC) on the north,***
4 ***east and south sides of the plant boundaries. The SNC committee is***
5 ***responsible for establishing the locations, timing and frequency of the***
6 ***off-site noise tests. For more information on the SNC, please refer to***
7 ***condition 19.***

- 8
- 9 11. Applicant will work with the Gilbert Unified School District to assist it in
10 converting as many as possible of its school bus fleet to green diesel or
11 other alternative fuel, as may be feasible and determined by Gilbert Unified
12 School District, and will contribute a minimum of \$330,000 to this effort.

13 ***Status ~ SRP has completed the activity required by this condition.***

- 14 12. Applicant shall actively work with all interested Valley cities, including at a
15 minimum, Tempe, Mesa, Chandler, Queen Creek and Gilbert, to fund a
16 Major Investment Study through the Regional Public Transit Authority to
17 develop concepts and plans for commuter rail systems to serve the growing
18 population of the East Valley. Applicant will contribute a maximum of
19 \$400,000 to this effort.

20 ***Status ~ Phase 2 of the Gilbert Transportation Study (the Gilbert Bicycle***
21 ***& Pedestrian Plan) is 98% complete. The Gilbert Transportation Study***
22 ***was developed to integrate with the Maricopa Association of***
23 ***Government's (MAG) Transit Study. Final comments from the Technical***
24 ***Advisory Committee (TAC) on the report have been incorporated in the***
25 ***Plan. The final Plan and Development Guidelines documents have been***
submitted to the Town of Gilbert. Town staff is working to schedule a
final presentation to the Town Council.

- 17 13. Within six months of approval of this Order by the Arizona Corporation
18 Commission, Applicant shall either relocate the gas metering facilities to the
19 interior of the plant site or construct a solid wall between the gas metering
20 facilities at the plant site and Warner Road. The wall shall be of such
21 strength and size as to deflect vehicular traffic (including a fully loaded
22 concrete truck) that may veer from Warner Road to the gas-metering site.

23 ***Status ~ SRP has completed the activity required by this condition.***

- 24 14. Applicant will use only SRP surface water, CAP water or effluent water for
25 cooling and power plant purposes. The water use for the plant will be
consistent with the water plan submitted in this proceeding and acceptable
to the Department of Water Resources. Applicant will work with the Town of
Gilbert to attempt to use available effluent water, where reasonably feasible.

Status ~ To date, SRP has delivered a total of 65,344 acre feet of CAP
water to GRUSP for future use via recovery from any SRP owned wells

1 *(Association or District) and delivered to SEP from the Eastern Canal*
2 *(or onsite District wells). SRP continues to be ahead of its storage*
3 *schedule and projects that SRP will continue to store CAP water in*
4 *GRUSP through 2011 for recovery and use. To meet ongoing*
5 *operational water demands, SEP continues to use SRP surface water*
6 *and CAP water (both directly and via recovery of storage credits from*
7 *SRP owned wells).*

- 8
9
10 15. Applicant agrees to comply with all applicable federal, state and local
11 regulations relative to storage and transportation of chemicals used at the
12 plant.

13 ***Status ~ SRP is in compliance with all applicable federal, state and local***
14 ***regulations relative to storage and transportation of chemicals used at***
15 ***the plant.***

- 16 16. Applicant agrees to maintain on file with the Town of Gilbert safety and
17 emergency plans relative to emergency conditions that may arise at the
18 plant site. On at least an annual basis Applicant shall review and update, if
19 necessary, the emergency plans. Copies of these plans will be made
20 available to the public and on Applicant's web site. Additionally Applicant
21 will cooperate with the Town of Gilbert to develop an emergency notification
22 plan and to provide information to community residents relative to potential
23 emergency situations arising from the plant or related facilities. Applicant
24 agrees to work with the Gilbert police and fire departments to jointly develop
25 on site and off-site evacuation plans, as may be reasonably appropriate.
This cooperative work and plan shall be completed prior to operation of the
plant expansion.

Status ~ SRP does and will continue to comply with all safety standards
including secondary containment for bulk materials (chemicals) and
development of evacuation procedures for plant personnel. A detailed
copy of the response plan is available at the Town of Gilbert Fire
Department as well as with the State Emergency Response Commission
(SERC) and the Maricopa County Local Emergency Planning Committee
(LEPC).

- 26 17. In obtaining air offsets required by EPA and Maricopa County, Applicant will
27 use its best efforts to obtain these offsets as close as practicable to the plant
28 site.

Status ~ SRP acquired emission reduction credits from the Phoenician
and Oak Canyon Manufacturing sufficient to satisfy the 72 ton VOC
offset requirement contained in the Santan air quality permit. In
addition, SRP, in cooperation with the Maricopa County Department of
Transportation (MCDOT), has obtained sufficient PM10 offsets for Unit 5
by paving roads in the east valley, starting with roads closest to the
plant site.

1 ***On December 6, 2005, SRP submitted a notice to Maricopa County Air***
2 ***Quality Division (MCAQD) indicating that MCDOT would complete initial***
3 ***chip sealing on all required road segments by December 8, 2005.***
4 ***Additionally, SRP submitted a letter to MCAQD confirming that the work***
5 ***was completed as planned on December 8, 2005. Enough road***
6 ***segments have been controlled to generate the required amount of***
7 ***PM10 offsets for Unit 6.***

8 ***All required offsets have been met for the Santan Expansion Project.***

- 9 18. In order to reduce the possibility of generation shortages and the attendant
10 price volatility that California is now experiencing, SRP will operate the
11 facilities consistent with its obligation to serve its retail load and to maintain a
12 reliable transmission system within Arizona.

13 ***Status ~ SRP's first priority in operating its generating stations,***
14 ***transmission system and distribution system is to safely supply a***
15 ***reliable, low cost source of power to its retail customers. The Santan***
16 ***Expansion Project will be operated in the same manner as current***
17 ***resources and is a significant element in SRP's plans to avoid the kind***
18 ***of price volatility that accompanied the California crisis.***

- 19 19. Beginning upon operation of the new units, Applicant will establish a citizens'
20 committee, elected by the CWG, to monitor air and noise compliance and
21 water quality reporting. Applicant will establish on-site air and noise
22 monitoring facilities to facilitate the process. Additionally Applicant shall
23 work with Maricopa County and the Arizona Department of Environmental
24 Quality to enhance monitoring in the vicinity of the plant site in a manner
25 acceptable to Maricopa County and the Arizona Department of
26 Environmental Quality. Results of air monitoring will be made reasonably
27 available to the public and to the citizens' committee. Applicant shall provide
28 on and off-site noise monitoring services (at least on a quarterly basis),
29 testing those locations suggested by the citizens' committee. The off-site air
30 monitoring plan shall be funded by the Applicant and be implemented before
31 operation of the plant expansion.

32 ***Status ~ The Santan Neighborhood Committee (SNC) held a meeting on***
33 ***October 19, 2005 where Santan personnel provided additional monthly***
34 ***data on emissions, water discharge and off-site noise readings taken***
35 ***since the last meeting. The group also discussed Unit 6 start-up***
36 ***activities. The next SNC meeting is scheduled for February 8, 2006.***

- 37 20. Applicant will explore, and deploy where reasonably practicable, the use of
38 available technologies to reduce the size of the steam plumes from the unit
39 cooling towers. This will be a continuing obligation throughout the life of the
40 plant.

1 ***Status ~ SRP explored the option of reduced plume cooling towers via***
2 ***the specification and bidding process for this equipment but found the***
3 ***limited availability, prohibitive cost and additional height requirements***
 of the plume abatement technology to supersede the potential benefits
 at this time. SRP will continue to monitor cooling tower technology.

- 4 21. SRP will, where practicable, work with El Paso Natural Gas Company to use
5 the railroad easements for the installation of the new El Paso gas line.

6 ***Status ~ SRP continues to review proposals to sell the SEP lateral to a***
7 ***third party.***

- 8 22. Other than the Santan/RS 18 lines currently under construction, Applicant
9 shall not construct additional Extra High Voltage transmission lines (115kV
10 and above) into or out of the Santan site, including the substation on the site.

11 ***Status ~ SRP will not construct additional Extra High Voltage***
12 ***transmission lines (no new circuits 115kv and above) into or out of the***
13 ***Santan site or substation on the site. However, some of the existing***
14 ***circuits may be bundled in the future as required.***

- 15 23. Applicant will replace all Town of Gilbert existing street sweepers with
16 certified PM10 efficient equipment. A PM10 efficient street sweeper is a
17 street sweeper that has been certified by the South Coast Air Quality
18 Management District (California) to comply with the District's performance
19 standards under its Rule 1186 (which is the standard referenced by the
20 Maricopa Association of Governments).

21 ***Status ~ SRP has completed the activity required by this condition.***

- 22 24. Applicant shall work in a cooperative effort with the Office of Environmental
23 Health of the Arizona Department of Health Services to enhance its
24 environmental efforts.

25 ***Status ~ A representative of the Arizona Department of Health Services***
 serves on the Santan Neighborhood Committee. The representative's
 role is to provide technical assistance and expertise to the citizens
 committee mentioned in condition 19. Such assistance will cover air,
 noise, and water quality issues.

25. Applicant shall operate, improve and maintain the plant consistent with
 applicable environmental regulations and requirements of the Environmental
 Protection Agency, the Arizona Department of Environmental Quality,
 Maricopa County and the Town of Gilbert.

Status ~ SRP has an environmental management system (EMS)
 designed to assure compliance with applicable laws and regulations.
 The Santan Generating Station is integrated in the SRP EMS.
 Procedures and Environmental Information Management Systems

1 ***(EIMS) have been modified to incorporate the new requirements***
2 ***associated with the Santan Expansion Project. Plant personnel***
3 ***responsible for meeting environmental compliance have received***
 training on the new requirements and a formal audit will be conducted
 within one year after Unit 6 startup.

- 4 26. Applicant shall actively work in good faith with Maricopa County in its efforts
5 to establish appropriate standards relative to the use of distillate fuels in
6 Valley generating facilities.

7 ***Status ~ SRP has completed the activity required by this condition.***

- 8 27. Applicant shall install continuous emission monitoring equipment on the new
9 units and will make available on its website emissions data from both the
10 existing and new units according to EPA standards. Applicant shall provide
11 information to the public on its website in order to assist the public in
12 interpreting the data, and provide viable information in a reasonable time
13 frame.

14 ***Status ~ SRP has installed continuous emission monitoring equipment***
15 ***on the new units. SRP is currently developing the presentation***
16 ***materials and graphics for the emissions data that will be posted on the***
17 ***Santan website.***

- 18 28. Applicant will comply with the provisions of the Intergovernmental
19 Agreement dated April 25, 2000 between Applicant and the Town of Gilbert,
20 as modified pursuant to this Certificate.

21 ***Status ~ There are eight SRP obligations noted on the IGA. The status***
22 ***of each obligation is as follows:***

23 ***Improvements to Warner Road and Val Vista Road ~ These***
24 ***improvements are complete.***

25 ***Screening of the Plant ~ All of the screening, with the exception of the***
26 ***northeast area and the southeast corner of the project site, is complete.***
27 ***The two areas of the site remaining to be landscaped must be left***
28 ***available for construction access and installation of underground***
29 ***utilities associated with the power plant construction. Screening in***
30 ***these areas will be completed upon completion of Unit 6 construction.***

31 ***Trail Extension ~ In the "Trails Area" to the east of the power plant,***
32 ***work is complete. The "Trails Area" includes a horse trail, unpaved***
33 ***equestrian resting areas complete with benches for the horse's rider,***
34 ***and a shared use path, surrounded by decorative masonry walls, path***
35 ***lighting, and new plantings of trees and shrubs.***

Rerouting of Canal at Ray Road ~ This canal modification is complete.

Training Tower Removal ~ This training tower was removed in the fall of

1 2000.

2 **Revegetation Along New RS 18 Line ~ SRP has restored any vegetation**
3 **damaged or destroyed along the RS 18 line as a result of the**
4 **construction of the line.**

5 **Dust Control Along Canals ~ SRP is in compliance with applicable PM-**
6 **10 standards along SRP canal banks.**

7 **Offsite Tree Planting ~ The offsite landscaping programs are complete.**
8 **See Condition 7 status for more details.**

- 9 29. During the proceeding neighbors to the plant site raise significant concern
10 about the impact of the plant expansion on residential property values. In
11 performing each of the conditions in this order Applicant, in conjunction
12 where applicable, with the Town of Gilbert and the plant site neighbors, shall
13 consider and attempt to maximize the positive effect of its activities on the
14 values of the homes in the surrounding neighborhoods.

15 **Status ~ SRP has invested \$20 million in community and site**
16 **improvements, including extensive landscaping to ensure compatibility**
17 **with the community. Conditions 7, 9 and 28 address SRP's**
18 **comprehensive landscaping plan that was developed by SRP's**
19 **landscape architect and approved by the CWG. Almost all of the**
20 **landscaping at the project site has been completed and funding for off-**
21 **site landscaping has been completed as well. The landscaping**
22 **provides attractive features and was designed to maximize the positive**
23 **effect on the surrounding neighborhoods.**

- 24 30. Applicant shall construct the auxiliary boiler stack at such height as may be
25 determined by air modeling requirements. Applicant shall situate the
26 auxiliary boiler stack so that it is not visible from off the plant site.

27 **Status ~ This condition is no longer applicable as SRP has decided not**
28 **to use an auxiliary boiler so no auxiliary boiler stack will be necessary.**

- 29 31. Applicant will construct the heat recovery steam generators ("HRSG")
30 approximately 15 feet below grade and will construct the HRSGs so that the
31 overall height of the HRSG module from the natural grade is no more than
32 80 feet.

33 **Status ~ SRP has completed the activity required by this condition.**

- 34 32. Applicant will complete the installation of the dry low NOX burners on the
35 existing units prior to the construction of the new units.

36 **Status ~ SRP has completed the activity required by this condition.**

- 37 33. Applicant shall not transfer this Certificate to any other entity for a period of

20 years from the date of approval by the Corporation Commission, other than as part of a financing transaction where operational responsibilities will remain with Applicant, and where Applicant will continue to operate the plant in accordance with this Certificate.

Status ~ SRP has no plans to transfer this Certificate to another entity.

34. Applicant shall post on its website, when its air quality permit application is submitted to the Maricopa County Environmental Services Department. Also, Applicant shall post on its website any official notice that may be required to be posted in newspapers for its air quality permit application.

Status ~ SRP has completed the activity required by this condition.

GRANTED this ____ day of February, 2001

ARIZONA POWER PLANT AND TRANSMISSION
LINE SITING COMMITTEE

By Paul A. Bullis
Its Chairman

BEFORE THE ARIZONA CORPORATION COMMISSION

In the matter of the Application of Salt)
River Project Agricultural Improvement and)
Power District in conformance with the)
requirements of Arizona Revised Statutes)
Sections 40-360-03 and 40-360.06, for a)
Certificate of Environmental Compatibility)
authorizing the Expansion of its Santan)
Generating Station, located at the intersection)
of Warner Road and Val Vista Drive,)
in Gilbert, Arizona, by adding 825 megawatts)
of new capacity in the form of three combined)
cycle natural gas units, and associated)
intraplant transmission lines.)
_____)

Case No. 105
Docket No. L-00000B-00-0105
Decision No. _____

1 The Arizona Corporation Commission (Commission) has conducted its review, as
2 prescribed by A.R.S. §40-360.07. Pursuant to A.R.S. §40-360.07(B), the Commission,
3 in compliance with A.R.S. §40-360.06, and in balancing the broad public interest, the
4 need for an adequate, economical and reliable supply of electric power with the desire
5 to minimize the effect thereof on the environment and ecology of the state;

6 The Commission finds and concludes that the Certificate of Environmental
7 Compatibility should be granted upon the additional and modified conditions stated
8 herein.

- 9 35. The Santan Expansion Project shall be required to meet the Lowest
10 Achievable Emission rate (LAER) for Carbon Monoxide (CO), Nitrogen
11 Oxides (Nox), Volatile Organic Carbons (VOCs), and particulate Matter
12 less than ten micron in aerodynamic diameter (PM10). The Santan
13 Expansion Project shall be required to submit an air quality permit
14 application requesting this LAER to the Maricopa County Environmental
15 Services Department.

16 ***Status ~ On February 10, 2003 the Maricopa County Environmental
17 Services Department issued an air quality permit for the Santan
18 Expansion Project. The air permit mandates the following Lowest
19 Achievable Emission Rates (LAER):***

- 20 • ***CO – 2 ppm w/o duct firing; 2 ppm w/ duct firing***
- 21 • ***NOx – 2 ppm w/o duct firing; 2 ppm w/ duct firing***
- 22 • ***VOC – 1 ppm w/o duct firing; 2 ppm w/ duct firing***
- 23 • ***PM10 - .01 lb/mmBtu***

- 24 36. Due to the plant's location in a non-attainment area, the Applicant shall not
25 use diesel fuel in the operation of any combustion turbine or heat recovery
steam generator located at the plant.

***Status ~ Since the issuance of the ACC order for the SEP Certificate of
Environmental Compatibility, SRP has not burned diesel fuel in the
existing Santan generating units. The new generating units associated
with the SEP will not have diesel fuel-burning capability.***

***On March 3, 2004, the Maricopa County Environmental Services
Department issued a revision to SRP's air quality permit to allow for the
use of ultra low sulfur fuel as an emergency fuel in the existing units.
The conditions in the air quality permit are identical to the requirements
for emergency fuels contained in Maricopa County's new air quality rule
for existing power plants (Rule 322), with the exception of the
requirement that SRP use ultra low sulfur fuel rather than low sulfur***

1 ***fuel. In addition, the revised air permit includes a separate condition***
2 ***stating that SRP cannot use the fuel unless previously authorized by***
3 ***the ACC. SRP will continue to fully comply with Condition 36 of the***
4 ***CEC that prohibits the use of diesel fuel in any Santan unit unless***
5 ***amended by the ACC on an emergency basis at some future time.***

- 6
- 7 37. In obtaining emissions reductions related to Carbon Monoxide (CO)
- 8 emissions, Applicant shall, where technologically feasible, obtain those
- 9 emission reductions onsite to the Santan Expansion Project.

10 ***Status ~ SRP has completed the activity required by this condition.***

- 11 38. Beginning upon commercial operation of the new units, Applicant shall
- 12 conduct a review of the Santan Generating facility operations and
- 13 equipment every five years and shall, within 120 days of completing such
- 14 review, file with the Commission and all parties in this docket, a report
- 15 listing all improvements which would reduce plant emissions and the costs
- 16 associated with each potential improvement. Commission Staff shall
- 17 review the report and issue its findings on the report, which will include an
- 18 economic feasibility study, to the Commission within 60 days of receipt.
- 19 Applicant shall install said improvements within 24 months of filing the
- 20 review with the Commission, absent an order from the Commission
- 21 directing otherwise.

22 ***Status ~ SRP will comply with the requirement for a review of***
23 ***technology that will reduce plant emissions every 5 years after***
24 ***commercial operation of the new units and will report such findings to***
25 ***the Commission and all parties in this docket.***

39. Applicant shall provide \$20,000 to the Pipeline Safety Revolving Fund on
- an annual basis, thus improving the overall safety of pipelines throughout
- the State of Arizona.

Status ~ In March 2005, a check for \$20,000 was sent to the Arizona
Corporation Commission, for deposit in the Pipeline Safety Revolving
Fund. This check satisfies compliance with this condition for the year
ending April 30, 2005. Subsequent checks will be distributed in the
March/April timeframe each year.

40. Where feasible, Applicant shall strive to incorporate local and in-state
- contractors in the construction of the three new generation units for the
- expansion project.

Status ~ Every effort has been made to incorporate local contractors for
this project. Over one hundred-eleven local or in-state contractors have
been engaged on jobs completed or in progress.

